



Test report - akumulator żelowy VIPOW 12V 4Ah

№:2014070905

Item No	12V4AH	Production Date	2014-7-14	Test Q'TY	5	
Test standard: GB2828-87 Normal test level II AQL Value: 2.5			A _c =0 Re =1	Inspector	Lijing	
	Test Item	Requirement of test	Test result			Judge
1	Appearance	No deform, clear mark	Well appearance			Pass
2	Terminal Volts	12.90~13.20	13.04~13.11			Pass
3	Dimension (±2mm)	L: 90 W: 70 H: 100 Th: 106	90*70*100*106			Pass
4	20 hours rate	0.2 A discharge T≥19.5h	21h 38m 48s			Pass
5	27min	4 A discharge T≥27min	38m 14s	37m 51s		Pass
6	3C	12 A discharge T≥7min	8m 49s	8m 35s		Pass
7	Weight(kg)		1.42	1.44	1.43	Pass
Conclusion	Pass		Review	Lizhangzuo	Approved	Linianshu

HW/QM-Q-C109