



Test raport - akumulator żelowy VIPOW 12V 2.2Ah

№:2014071315

Item No	12V2.2AH	Production Date	2014-7-14	Test Q'TY	5	
Test standard: GB2828-87 Normal test level II AQL Value: 2.5			A _c =0 Re =1	Inspector	Lijing	
	Test Item	Requirement of test	Test result			Judge
1	Appearance	No deform, clear mark	Well appearance			Pass
2	Terminal Volts	12.90~13.20	13.09~13.15			Pass
3	Dimension (±2mm)	L: 178 W: 35 H: 61 Th: 67	178*35*61*67			Pass
4	20 hours rate	0.245 A discharge T≥19.5h	19h 50m 12s			Pass
5	27min	2,2 A discharge T≥27min	33m 34s	34m 53s		Pass
6	3C	6.6 A discharge T≥7min	7m 49s	7m 28s		Pass
7	Weight(kg)		0.92	0.92	0.92	Pass
Conclusion	Pass		Review	Lizhangzuo	Approved	Linianshu

HW/QM-Q-C109